



TEXAS RE

CIP-012-1 R1

**Devin Ferris
Manager, CIP Compliance Monitoring**

April 4, 2025

Risk Element Areas of Focus: Remote Connectivity

CIP-012-1 R1: Communications between Control Centers

Mitigation of the risks posed by unauthorized disclosure, unauthorized modification, and loss of availability of data used for Real-time Assessment and Real-time monitoring while such data is being transmitted between any applicable Control Centers.

CIP-012-1

R1

Balancing Authority
Generator Operator
Generator Owner
Reliability Coordinator
Transmission Operator
Transmission Owner



CIP-012-1 R1

Part 1.1

Identification of security protection used to mitigate the risks posed by unauthorized disclosure and unauthorized modification of Real-time Assessment and Real-time monitoring data while being transmitted between Control Centers

Part 1.2

Identification of where the Responsible Entity applied security protection for transmitting Real-time Assessment and Real-time monitoring data between Control Centers

Part 1.3

If the Control Centers are owned or operated by different Responsible Entities, identification of the responsibilities of each Responsible Entity for applying security protection to the transmission of Real-time Assessment and Real-time monitoring data between those Control Centers



CIP-012-2 – Communications Between Control Centers

Effective
Date

July 1, 2026

Additions

Loss of availability



The background of the slide features a blurred image of the Texas state flag on the left and a close-up of a wind turbine's hub and blades on the right. The blades are white with red tips. A dark blue rounded rectangle is centered over the image.

Questions?



TEXAS RE

Ensuring electric reliability for Texans