



**TEXAS RE**

# **Reliability Performance and Regional Risk Assessment**

**David Penney**  
**Director, Reliability Services**

**June 16, 2025**

# Antitrust Admonition

**Texas Reliability Entity, Inc. (Texas RE) strictly prohibits persons participating in Texas RE activities from using their participation as a forum for engaging in practices or communications that violate antitrust laws. Texas RE has approved antitrust guidelines available on its website. If you believe that antitrust laws have been violated at a Texas RE meeting, or if you have any questions about the antitrust guidelines, please contact the Texas RE General Counsel.**

**Notice of this meeting was posted on the Texas RE website and this meeting is being held in public. Participants should keep in mind that the listening audience may include members of the press, representatives from various governmental authorities, and industry stakeholders.**



# Upcoming Texas RE Events



talk with  
TEXASRE

June 24, 2025

Modeling and  
Model Verification



talk with  
TEXASRE

July 22, 2025

Extreme Weather  
Response Risk  
Element



talk with  
TEXASRE

August 5, 2025

Cybersecurity  
Threats





# Upcoming Texas RE Events



July 16, 2025

Evolving Grid  
Workshop



September 17, 2025

Q3 MRC, AGR&F, and  
Board Meetings



October 1, 2025

Winter  
Weatherization  
Workshop



# Upcoming ERO Enterprise Events

**NERC**

NORTH AMERICAN ELECTRIC  
RELIABILITY CORPORATION



**Date**

**Event**

**June 16**

Technical Talk with RF (RF)

**June 19**

Reliability & Security Monthly Update (WECC)

**July 17**

Reliability & Security Monthly Update (WECC)

**July 21**

Technical Talk with RF (RF)

slido

Product

Solutions

Pricing

Resources

Enterprise

Log In

Sign Up

## Joining as a participant?

# Enter event code

Join an existing event

#TXRE

The ultimate Q&A and polling platform

## Give a voice to your audience, wherever they are.

Create your own Slido event

[Watch a video](#) or [Schedule a demo](#)



# Key Findings

**Efforts to reduce inverter-based resource risks continue**

**Increased risk due to large load integration**

**Large load impact on future reserve margins**


**Reduced impact from cold weather on generators**

**Artificial intelligence presents new challenges**





# Reliability Performance and Regional Risk Assessment



## Performance Analysis and Key Risk Areas

- **Grid Transformation**
  - Resource Adequacy and Performance
  - Bulk Power System Planning
  - Protection and Control Systems
  - Situational Awareness Challenges
  - Human Performance
  - Changing Resource Mix
- Resilience to Extreme Events
- Cyber and Physical Security
- Critical Infrastructure Interdependencies





# Reliability Performance Metrics

<b>Improving</b> (Improving trend compared to previous 4 years or improved event performance of observed conditions)	<b>Stable or No Change</b> (Minimal or no change compared to previous 4 years)	<b>Monitoring</b> (Declining trend compared to previous 4 years or specific negative event performance issues)	<b>Actionable</b> (Declining trend for two or more consecutive years or significant negative event performance)
---	---	---	--

Key Performance Indicator with Description	2024 Performance & Trend Results
<b>Resource Adequacy</b> Measures potential resource adequacy issues by analysis of planning reserve margin and energy emergency alerts	Reserve margins show resource deficiencies due to integration of large loads Resource weatherization resulted in sustained performance during cold weather events
<b>Transmission Performance</b> Measures transmission performance by analysis of transmission outage rates and Interconnection Reliability Operating Limits (IROL) exceedances	345 kV & 138 kV transmission outage rates IROL Exceedances
<b>Resource Performance</b> Measures generation performance by analysis of generator outage rates, primary frequency response, and balancing contingency events	Resource outages/gas restrictions during cold weather EFOR decreased in 2024, long term rate increase Primary frequency response No balancing contingency event failures
<b>Grid Transformation</b> Measures potential issues related to grid transformation by analysis of system inertia and ramping	Solar ramp magnitudes continue to increase Voltage ride through for IBRs and large loads Inertia levels are stabilizing Synchronous generator retirements slowed
<b>Protection System Performance</b> Measures Protection System performance by analysis of Protection System Misoperations	Misoperations due to incorrect settings continued to decrease in 2024 Misoperation rate decreased in 2024, remains less than overall NERC Misoperation rate
<b>Human Performance</b> Measures transmission outages, generation outages, and Protection System Misoperations caused by human error	Reduction in transmission and generation outage rates from human error Human error primary causal factor in Misoperations and events
<b>Situational Awareness</b> Measures situational awareness by analysis of state estimator convergence rates, event analysis, and telemetry performance	Eight loss of situational awareness events (up from four) State Estimator convergence rate remained stable

## Performance Metrics

- Resource deficiencies and negative reserve margins forecasted in future years due to integration of large loads
- Improvements noted in resource weatherization and cold weather resiliency
- Improvements noted in frequency response due to integration of battery energy storage
- Solar down-ramp magnitude continues to increase
- Inverter-based resource ride-through continues to be a point of emphasis
- Voltage ride-through issues with large loads
- Misoperation rates improving but human performance continues to be primary causal factor in both misoperations and system events
- Increased number of loss of situational awareness events



# 2025 Risk Focus Areas

CONSEQUENCE/ IMPACT		LIKELIHOOD (L)				
		L1	L2	L3	L4	L5
		VERY LIKELY	UNLIKELY	POSSIBLE	LIKELY	ALMOST CERTAIN
C5	SEVERE					
C4	MAJOR			Supply Chain	Disorganized Integration of Large Loads	
				Energy Availability		
			Extreme Weather & Resource Weatherization	Gas Supply Restrictions During Cold Weather	IBR Ride- Through	
C3	MODERATE		Provision of Essential Reliability Services from a Changing Resource Mix	Remote Access		
			Facility Ratings	Inaccurate Resource Modeling		
			Artificial Intelligence		Physical Security	
C2	MINOR					
C1	NEGLIGIBLE					

RISK LEVEL			
LOW	MODERATE	HIGH	VERY HIGH

## Risk Focus Areas for 2025

- Continuous Evaluation of Emerging Risks
- Priorities Based on Likelihood and Impact
- Major Areas
  - IBR Ride-Through
  - Physical Security
  - Remote Access Threats and Vulnerabilities
  - Gas-Electric Interdependencies
  - Supply Chain
  - Resource Modeling
- New for 2025: Artificial Intelligence



# Risk Focus Area Follow-up and Outreach

## 2024 Risk and CMEP IP Focus Areas

Inverter-Based Resource Ride Through

Provision of Essential Reliability Services from a Changing Resource Mix

Energy Reliability Planning

Inaccurate Resource Modeling

Remote Access

Supply Chain

Physical Security

Extreme Weather & Resource Weatherization

Facility Ratings

Gas Supply Chain Restrictions during Cold Weather


Integration of Large Loads

Incident Response

Stability Studies


- Eighteen Talk with Texas RE webinars on risk focus area topics
- Winter Weatherization Workshop
- Cyber and Physical Security Workshop
- NERC Alert issued on IBR model quality
- Multiple entity engagements

Entity Engagements by Risk Element




# Resource and Energy Adequacy

Summer Reserve Estimates




Source: ERCOT




- PUCT Reliability Standard
- Texas Energy Fund Projects
- 765kV Transmission Projects
- Energy Assessment pilot study kick off May 2025
- NERC Interregional Transfer Capability Study
  - Energy deficiencies identified in multiple weather years studied

Metric	2026	2026	2028	2028
	Summer	Winter	Summer	Winter
LOLE (days/year)	0.38	0.51	0.05	0.04
LOLH (hours/year)	1.41	1.57	0.18	0.16
EUE (MWh)	10,985	11,090	857	781
Max Hourly EUE (MWh)	29,124	29,266	17,762	16,851
Max EUE Duration (Hr)	15	16	12	11

Texas - 2024




Texas - 2034





# Large Load Integration

Actual and Projected Large Load Growth 2022-2028



**NERC**  
NORTH AMERICAN ELECTRIC  
RELIABILITY CORPORATION

## Incident Review

Considering Simultaneous Voltage-Sensitive Load Reductions

### Primary Takeaways

Operators and planners of the Bulk Electric System (BES) should be aware of the risks and challenges associated with voltage-sensitive large loads that are rapidly being connected to the power system. Specifically, when considering data centers and cryptocurrency mining facilities, entities should be aware of the potential for large amounts of voltage-sensitive load loss during normally cleared faults on the BES. Voltage-sensitive data center-type loads have increased on the system and are predicted to continue growing rapidly. The 2024 NERC Long-Term Reliability Assessment (LTRA) documents and discusses this potential growth of data center-type loads. This vignette highlights this load-loss potential based on analysis of a recent event in the Eastern Interconnection and offers some considerations for BES operators, planners, and regulators concerning identifying and mitigating the potential reliability effects and risks presented by these large voltage-sensitive load losses for future operations.

### Summary of Incident

A 230 kV transmission line fault led to customer-initiated simultaneous loss of approximately 1,500 MW of voltage-sensitive load that was not anticipated by the BES operators. The electric grid has not historically experienced simultaneous load losses of this magnitude in response to a fault on the system, which has historically been planned for large generation losses but not for such significant simultaneous load losses. Simultaneous large load losses have two effects on the electric system: First, frequency rises on the system as a result of the imbalance between load and generation; second, voltage rises rapidly because less power is flowing through the system. In this incident, the frequency did not rise to a level high enough to cause concern. The voltage also did not rise to levels that posed a reliability risk, but operators did have to take action to reduce the voltage to within normal operating levels. However, as the potential for this type of load loss increases, the risk for frequency and voltage issues also increases. Operators and planners should be aware of this reliability risk and ensure that these load losses do not reach intolerable levels.

### Incident Details

At approximately 7:00 p.m. Eastern on July 10, 2024, a lightning arrester failed on a 230 kV transmission line in the Eastern Interconnection, resulting in a permanent fault that eventually "locked out" the transmission line. The auto-reclosing control on the transmission line was configured for three auto-reclose attempts staggered at each end of the line. This configuration resulted in 6 successive system faults in an 82-second period. The protection system detected these faults and cleared them properly. The shortest fault duration was the initial fault at 42 milliseconds, and the longest fault duration was 66 milliseconds. The voltage magnitudes during the fault ranged from .25 to .40 per unit in the load-loss area.

**NERC**  
NORTH AMERICAN ELECTRIC  
RELIABILITY CORPORATION


## Large Loads Task Force (LLTF)

Work Plan

<b>Website:</b> <a href="#">LLTF</a>	<b>Chair:</b> Matthew Vieth, AEP	<b>NERC Leads:</b> Jack Gibbried and Evan Mickelson
<b>Hierarchy:</b> Reports to RSTC	<b>Vice-chair:</b> Agee Springer, ERCOT	<b>Scope Approved:</b> August 2024

#	Task Description	Target Completion	Status
1	<b>White Paper: Characteristics and Risks of Emerging Large Loads</b> White Paper on the unique characteristics and risks associated with emerging large loads. This paper will leverage the NERC Framework to address known and emerging reliability and security risks to identify, validate, and prioritize potential reliability risks related to the integration of emerging large loads.	Q2 – 2025	In Progress
2	<b>White Paper: Assessment of gaps in existing practices, requirements, and Reliability Standards for Emerging Large Loads</b> White Paper assessing whether existing engineering practices, requirements, and Reliability Standards can adequately capture and mitigate reliability impact(s) of large loads interconnected to the BES. The paper will also highlight gaps in load modeling practices that LMWG can leverage to take further action to improve load modeling.	Q4 – 2025	In Progress
3	<b>Reliability Guideline: Risk Mitigation for Emerging Large Loads</b> Reliability Guideline identifying risk mitigation including improvements to existing planning, and operation processes and interconnection requirements for large loads. Guidance may include recommended improvements to modeling practices, analyses, coordination and data collection efforts, real time monitoring and event analysis.	Q2 – 2026	Not Started

## Large Power Electronic Load Ride-Through Events November 2023 - Present



**ercot**  
PUBLIC

8

- NERC Large Load Task Force activities
- Issues with future reserve margins due to anticipated large load growth
- Multiple voltage-sensitive load reduction events
- Price-responsive load swings
- Regulation exhaustion during large load swings
- No defined registration criteria

# Inverter-Based Resource Risks

185 FERC ¶ 61,042  
UNITED STATES OF AMERICA  
FEDERAL ENERGY REGULATORY COMMISSION

18 CFR Part 40

[Docket No. RM22-12-000; Order No. 901]

Reliability Standards to Address Inverter-Based Resources

(Issued October 19, 2023)

**NERC**  
NORTH AMERICAN ELECTRIC  
RELIABILITY CORPORATION

## 2022 Odessa Disturbance

Texas Event: June 4, 2022  
Joint NERC and Texas RE Staff  
December 2022

**NERC**  
NORTH AMERICAN ELECTRIC  
RELIABILITY CORPORATION

## 2022 California Battery Energy Storage System Disturbances

California Events: March 9 and April 6, 2022  
Joint NERC and WECC Staff Report  
September 2023

**RELIABILITY**



**RELIABILITY | RESILIENCE | SECURITY**



3353 Peachtree Road NE  
Suite 600, North Tower  
Atlanta, GA 30326  
404-446-2560 | www.nerc.com


- Increased reliance on IBRs to meet load
- NOGRR245 and 255 approval
- FERC Order 901 projects
- Smaller disturbances still occurring in ERCOT
- Four large IBR disturbances in WECC
- NERC Alert on IBR model quality
- Need for Grid-Forming battery capabilities

### High Voltage Threshold Settings Model vs Reported

As-left control setting matches model parameter  
As-left control setting does not match model parameter

Total

# of Facilities	%
38	28%
99	72%
137	100%




### Low Voltage Threshold Settings Model vs Reported



As-left control setting matches model parameter  
As-left control setting does not match model parameter

Total


# of Facilities	%
43	32%
90	68%
133	100%






# Inertia and Frequency Response



- Continued shift in inertia levels as resource mix changes
- Lowest hourly inertia level of 129.9 GW-sec in 2024
- Frequency response improvements noted due to higher levels of PFR capacity from integration of batteries



# Solar and Net Load Ramping





- Solar and net load ramp rates continue to increase
- Non-spin and ECRS deployments occasionally used during steep ramp hours
- Battery resources continue to provide valuable capability during ramp hours

Ramping Variability 2024	Load	Wind Gen	Solar Gen	Net Load
Maximum One-Hour Increase	5,487 MW	5,868 MW	12,053 MW	14,432 MW
Maximum One-Hour Decrease	-4,730 MW	-6,521 MW	-10,697 MW	-11,301 MW




# Generator Outage Rates

- Decrease in thermal EFOR rates in 2024, but long-term trend is still increasing
- Wind resource EFOR rates remained flat in 2024
- Initial year of collecting solar resource EFOR rates




# Protection System Misoperations




- Overall Misoperation rate trending lower, from 6.0% in 2020 to 4.3% in 2024
- Incorrect settings, logic, and design errors remain the largest cause
- Region compares favorably with NERC overall and other regions

138kV Percent Misoperations and 345kV Percent Misoperations by Quarter





# Human Performance

Outage Rates Initiated by Human Error




- Human performance remains primary causal in Protection System Misoperations
- Outage rates caused by human error for 138 kV circuit outages and transformers showed a decrease in 2024 compared to prior years.
- Outage rates caused by human error for generators and 345 kV circuit outages increased in 2024 but remained within the long-term trend averages.
- 54% of event root and contributing causes related to human or organizational performance




# Physical Security

Count of Physical Security Events by Issue and Year

Year ● 2020 ● 2021 ● 2022 ● 2023 ● 2024



Count of Physical Security Events by Location



## Significant events

- Transformer outage when control cables were cut and stolen from a cable tray
- Multiple transmission lines damaged due to gunfire
- Transformer radiator damage and oil leak due to gunfire
- Primary protective relaying and communications affected due to cut fiber optic cable
- Individuals drove through the gate at a coal power plant after being instructed by security to turn around
- Multiple wind turbines damaged by gunfire







# Resilience and Extreme Day Analysis

## Generation and Transmission outage severity and duration continues to be driven by weather and failed equipment

Generation Extreme Day Analysis	Number of Generation Outage Events on Extreme Day	Leading Causes for Extreme Day	Cumulative Outage Duration on Extreme Day	Cumulative MW Impact on Extreme Day	Cumulative GWh Impact on Extreme Day
8/27/2017	41	Weather	22,798 hours	10,107 MW	2,917.5 GWh
1/16/2018	84	Balance of Plant/Fuel	2,891 hours	11,893 MW	517.8 GWh
5/11/2019	36	Turbine Generator	1,626 hours	6,449 MW	282.5 GWh
7/1/2020	44	Auxiliary systems	3,352 hours	8,251 MW	247.9 GWh
2/15/2021	187	Weather	6,937 hours	35,241 MW	1,204.1 GWh
12/23/2022	164	Weather	2,180 hours	23,163 MW	321.8 GWh
1/30/2023	65	Turbine Generator/Fuel	2,745 hours	9,327 MW	332.4 GWh
1/15/2024	81	Fuel, Weather	885 hours	9,292 MW	86.3 GWh



2024 was the second highest level of customer outages in the last fifteen years



The background of the slide features a blurred image of the Texas state flag on the left and a close-up of a wind turbine's hub and blades on the right. The blades are white with red tips. A dark blue rounded rectangle is centered over the image.

# Questions?



**TEXAS RE**

Ensuring electric reliability for Texans